



Oakfield Care Home

ACoP L8 / HSG274

3 Marine Drive, Lancaster LA2 6DZ · Single site · 18 outlets

MONTHLY SENTINEL TEMPERATURES (TARGET: HOT \geq 50C, COLD \leq 20C)

Kitchen hot (sentinel)	55.4 C	PASS
Room 6 basin hot (sentinel)	52.1 C	PASS
Laundry cold (sentinel)	17.2 C	PASS
Reception cold (sentinel)	18.0 C	PASS

WEEKLY FLUSHING LOG (LITTLE-USED OUTLETS)

Spare bathroom basin and bath	Flushed 12 Jun 2026	DONE
Room 11 shower	Flushed 12 Jun 2026	DONE
Guest WC	Flushed 12 Jun 2026	DONE

ANNUAL REVIEW

Risk assessment review	Completed 04 Mar 2026	ON FILE
Next review due	04 Mar 2027	SCHEDULED

About this sample

Illustrative only, with example data. AquaLog keeps and produces these records. It does not replace a competent person's risk assessment where one is required.